



Fire Extinguisher Inspection Certificate APRIL 2025

This certificate confirms that we have completed the maintenance service of your fire equipment listed in accordance with BS 5306: Part 3: 2000

Extract from British Standard 5306-3: 2000

It is recommended that regular visual inspections of all portable fire extinguishers are carried out by the user or users representative, no less than monthly.

The Fire Safety Order 2005 suggest that good practice is to check for correct installation and apparent function on a weekly basis. Inspections should include checks that each extinguisher is located in the designated place, is unobstructed, visible and its operating instructions face outwards, has operating instructions which are clean and legible, is not obviously damaged, has a reading in the operable range or position of any pressure gauge or indicator fitted and has seals and tamper indicators which are not broken or missing.

The user should arrange for corrective action where necessary.

Registered business	Site address (if applicable)	Customer address
Firecheck North West Limited Firecheck House 9 Avon Road Culcheth Warrington Cheshire		Croft Village Hall 5 Mustard Lane Croft Warrington Cheshire WA3 7DG
S .		

Fire Extinguishers							
		Result					
Location	Service Type	ID No.	PASS	FAIL	Comments		
Entrance	9 Litre Gas/Water	1	PASS				
Main Hall	6 Litre AFFF Foam	2	PASS				
Main Hall	6 Litre Water Spray Mist (A, F, E)	3	PASS				
Main Hall	6 Litre AFFF Foam	4	PASS				
Main Hall	2 Kg Carbon Dioxide	13	PASS				
Stage	2 Kg Carbon Dioxide	5	PASS				
Kitchen	2 Kg Carbon Dioxide	6	PASS				
Kitchen	Fire Blanket	7	PASS				
Birch Hall	6 Litre AFFF Foam	8	PASS				
Kitchen Birch Hall	2 Kg Carbon Dioxide	9	PASS				
Kitchen Birch Hall	Fire Blanket	10	PASS				





Front Boiler Room	2 Kg ABC Dry Powder	11	PASS				
Rear Boiler Room	2 Kg ABC Dry Powder	12	PASS				
13							
Engineer Name:	Name:		Date: April 2025				
Mike Schofield				NEXT ANNUAL SERVICE: APRIL 2026			