

Commercial Gas Safety Record

This record can be to document the outcome of the checks and tests required by The Gas Safety (Installation and Use) Regulations. Some of the outcomes are as a result of visual inspection only and are recorded where appropriate.



Registered Business	Site Address	Landlord/Agent/Homeowner
Aquila Heating & Plumbing Ltd 410 Europa Boulevard, Westbrook Warrington, Cheshire, WA5 7TR +44 1925 234450 Gas Safe Reg No: 571057	Croft Memorial Village Hall, Mustard Lane Warrington Cheshire WA3 7BQ	Croft Village Hall Croft Memorial Village Hall, Mustard Lane Warrington Cheshire WA3 7BQ

No.	Location	Type	Make/ Model	Serial No.	Flue type	Operating pressure or heat input	Safety device(s) operating correctly
1	Boiler Room	Heat Only Boiler	Vaillant Ecotec plus 438		RS	17 mbar	Pass
2	Boiler Room	Heat Only Boiler	Vaillant Ecotec pro		RS	20 mbar	Pass
3							
4							

No.	Ventilation satisfactory	Visual condition of flue & termination	Flue operation checks	Flue spillage	Combustion analyser reading	Serviced	Safe to use
1	Yes	Pass	Pass	N/A	.0011	Yes	Yes
2	Yes	Pass	Pass	N/A	.0012	Yes	Yes
3							
4							

Gas installation line diagram fixed near the primary meter?	N/A	Is the meter installation accessible?	Yes	Warning Notice has been raised and labelled attached?	No
Is the gas installation line diagram current?	N/A	Is the meter room/compartment secure?	Yes	Warning notice number	
Are adequate emergency/isolation valves fitted?	Yes	Is the meter room/compartment clear of combustibles?	Yes	Has a responsible person been advised?	No
Are emergency/isolation valve handles in place & labelled?	Yes	Is the meter room/compartment lock key clearly labelled?	Yes	Name of responsible person?	

Commercial Gas Safety Record

This record can be to document the outcome of the checks and tests required by The Gas Safety (Installation and Use) Regulations. Some of the outcomes are as a result of visual inspection only and are recorded where appropriate.



Is the pipework colour coded/identified?	Yes	Is the emergency control valve labelled with the direction of operation?	Yes
Is the gas installation electrically cross bonded?	Yes	Emergency control valve complete with emergency notice?	Yes
Is the pipework adequately supported?	Yes	Is the meter adequately supported?	Yes
Has a gas strength/gas tightness test been carried out?	Yes		

Comments

No.	Defects Identified	Warning/Advice Notice Issued	Remedial Action Taken
1	N/A	N/A	N/A
2			
3			
4			

Further Readings												
No.	CO PPM (min)	CO ₂ % (min)	O ₂ % (min)	Ratio (min)	CO PPM (max)	CO ₂ % (max)	O ₂ % (max)	Ratio (max)	Working pressure at meter	Working appliance pressure	Gross flue gas temperature	Gas rate (if applicable)
1					96	8.86		.0011		17		
2					107	9.28		.0012		20		
3												
4												

Commercial Gas Safety Record

This record can be to document the outcome of the checks and tests required by The Gas Safety (Installation and Use) Regulations. Some of the outcomes are as a result of visual inspection only and are recorded where appropriate.



Gas Engineer Details	Report Received By	Certificate Information
<p>Name: Adrian Burgess Gas Safe ID: 5472988 Signature:</p> 	<p>Received by: No person present Name: Signature:</p>	<p>Certificate Number: 8629 Date of certificate: 05/05/26 Next service due: 05/05/27</p>